

IEC**IECEE**

TM

Ref. Certif. No.

CN72533

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Modular Residual Current Devices

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Yueqing Economic Development Branch of Zhejiang Tengen
Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

Vigi-MH;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th
Edition);IEC 60947-1:2007;IEC
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which
forms part of this Certificate

(2025)FQIIDQ-1366

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jul.16,2025

Signature:

Xie ZhaoXu



Vigi-MH;
Uimp: 8kV;
Ui: 1250V;
Ue: AC415V;
In: $\leq 250\text{A}$; $I\Delta n$: 30mA (only for non-delay type), 100mA, 500mA, 1A, 2A; $I\Delta n_{0.5} = 0.5 I\Delta n$;
Rated residual operation type: Type A;
Icc: 65kA; $I\Delta c$: 16.25kA;
Pole number: 3P, 4P;
Primary conductor structure: Terminal type Matching circuit breakers:
TeM7-125, TeM7-250, TeM7-125HU, TeM7-250HU; TeM7E-125L, TeM7E-125M, TeM7E-125H, TeM7E-125S, TeM7E-125R, TeM7E-160L, TeM7E-160M, TeM7E-160H, TeM7E-160S, TeM7E-160R, TeM7E-250L, TeM7E-250M, TeM7E-250H, TeM7E-250S, TeM7E-250R

Page 1 of 1

Additional information (if necessary)

Date:

Jul. 16, 2025

Signature:


Xie ZhaoXu